INSTRUCTION MANUAL

PARAMETER GENERATOR (PC programmable)

MODEL M5XMST

BEFORE USE

Thank you for choosing us. Before use, please check contents of the package you received as outlined below. If you have any problems or questions with the product, please contact our sales office or representatives.

■ PACKAGE INCLUDES:

MODEL NO.

Confirm Model No. marking on the product to be exactly what you ordered.

■INSTRUCTION MANUAL

This manual describes necessary points of caution when you use this product, including installation, connection and basic maintenance procedures.

The M5XMST is programmable using the PC Configurator Software. For detailed information on the PC configuration, refer to the M5CFG users manual. The M5CFG PC Configurator Software is downloadable at our web site.

POINTS OF CAUTION

■ CONFORMITY WITH EU DIRECTIVES

- The equipment must be mounted inside a panel.
- The actual installation environments such as panel configurations, connected devices, connected wires, may affect the protection level of this unit when it is integrated in a panel system. The user may have to review the CE requirements in regard to the whole system and employ additional protective measures* to ensure the CE conformity.
 - * For example, installation of noise filters and clamp filters for the power source, input and output connected to the unit, etc.

■ POWER INPUT RATING & OPERATIONAL RANGE

 Locate the power input rating marked on the product and confirm its operational range as indicated below: 24V DC rating: 24V ±10%, ≤ 1W

■ GENERAL PRECAUTIONS

• Before you remove the unit or mount it, turn off the power supply and input signal for safety.

ENVIRONMENT

- Indoor use.
- When heavy dust or metal particles are present in the air, install the unit inside proper housing with sufficient ventilation.
- Do not install the unit where it is subjected to continuous vibration. Do not subject the unit to physical impact.
- Environmental temperature must be within -20 to $+65^{\circ}C$ (-4 to $+149^{\circ}F$) with relative humidity within 30 to 90% RH in order to ensure adequate life span and operation.


■ WIRING

- Do not install cables close to noise sources (relay drive cable, high frequency line, etc.).
- Do not bind these cables together with those in which noises are present. Do not install them in the same duct.
- Install lightning surge protectors for those wires connected to remote locations.

■ AND


• The unit is designed to function as soon as power is supplied, however, a warm up for 10 minutes is required for satisfying complete performance described in the data sheet.

COMPONENT IDENTIFICATION



SETTING

■ FRONT VIEW



A) Monitor output

Setting value of the output signal is output as 0 - 1 V DC between the terminal 3 and 4, check with the tester. For example, set monitor output to 0.5 V to output 50 %. B) Output


Set miss-operation preventer to UNLOCK side. Set output signal by operating UP/DOWN control SW while checking monitor output. After setting, set miss-operation preventer to LOCK side. Operation of the UP/ DOWN control SW is disabled. At that time, setting values are stored to the non-volatile memory (write/erase cycle endurance: less than 20 000).

INSTALLATION

Set the unit so that its DIN rail adapter is at the bottom.

■ MOUNTING THE UNIT ON A DIN RAIL


- A) Hang the upper hook at the rear side of unit on the DIN rail.
- B)Push in the lower in keeping pressing the unit to the DIN rail.



■ REMOVING THE UNIT

A) Pull down the DIN rail adaptor using a minus screwdriver.


B) Pull out the lower part of the unit.C) Remove the upper part from the DIN rail.



TERMINAL CONNECTIONS


Connect the unit as in the diagram below or refer to the connection diagram on the side of the unit.

EXTERNAL DIMENSIONS unit: mm [inch]



 \cdot When mouning, no extra space is needed between units.

■ CONNECTION DIAGRAM




WIRING INSTRUCTIONS

■ SCREW TERMINAL Torque: 0.8 N·m

EXTERNAL VIEWS

■ LEFT VIEW



OUTPUT RANGING

The internal DIP switch setting is required to select output types before setting a precise output range using PC Configurator Software (model: M5CFG).

For detailed information on the PC configuration, refer to the M5CFG users manual.

Table 1. DIP switch setting: Output type

Output Type	SW1					
	1	2	3	4	5	6
0 – 20 mA DC	ON	OFF	OFF	OFF	ON	OFF
-5 - +5 V DC	OFF	ON	ON	OFF	OFF	ON
-10 – +10 V DC	OFF	ON	OFF	ON	OFF	ON

CHECKING

- 1) Terminal wiring: Check that all cables are correctly connected according to the connection diagram.
- 2) Check DIP switch setting.
- 3) Power input voltage: Check voltage across the terminal 7-8 with a multimeter.
- 4) Output: Check that the load resistance meets the described specifications.
- 5) Monitor output voltage: Check voltage across the terminal 3 – 4 with a multimeter.

POWER INDICATOR LED

The transmitter is provided with a power indicator LED which blinks in different patterns indicating various operating status.

The following figure indicates typical patterns.

TRANSMITTER STATUS	LED ON OFF PATTERNS		
Normal			
Downloading the setting			
Range setting			
Fine adjusting			
Supplying a fixed output			
Abnormal Operation			
(corruption of configuration data)			
	80ms		

MAINTENANCE

Regular calibration procedure is explained below:

■ CALIBRATION

Warm up the unit for at least 10 minutes. Set setting value as 0%, 25%, 50%, 75% and 100%. Check that the output signal and monitor signal for the respective input signal remains within accuracy described in the data sheet. When the output and monitor signal are out of tolerance, recalibrate the unit using the PC Configurator Software (model: M5CFG).

LIGHTNING SURGE PROTECTION

We offer a series of lightning surge protector for protection against induced lightning surges. Please contact us to choose appropriate models.