## INSTRUCTION MANUAL

# TOTALIZED PULSE INPUT MODULE

(screw terminal block; Pi 2 points)

MODEL

R5T-PA2

## **BEFORE USE ....**

Thank you for choosing M-System. Before use, please check contents of the package you received as outlined below. If you have any problems or questions with the product, please contact M-System's Sales Office or representatives.

### **■ PACKAGE INCLUDES:**

Totalized pulse input module .....(1)

#### ■ MODEL NO.

Confirm Model No. marking on the product to be exactly what you ordered.

#### **■ INSTRUCTION MANUAL**

This manual describes necessary points of caution when you use this product, including installation, connection and basic maintenance procedures.

# **POINTS OF CAUTION**

## **■ CONFORMITY WITH EU DIRECTIVES**

- The equipment must be mounted inside the instrument panel of a metal enclosure.
- The actual installation environments such as panel configurations, connected devices, connected wires, may affect the protection level of this unit when it is integrated in a panel system. The user may have to review the CE requirements in regard to the whole system and employ additional protective measures to ensure the CE conformity.

### **■ HOT INSERTION/REMOVAL OF MODULES**

Removing or replacing modules does not affect other modules on the same backplane. It is possible to replace them without removing the power supply. However, replacing multiple modules at once may greatly change line voltage levels. We recommend that you replace them one by one.

### **■ GENERAL PRECAUTIONS**

DO NOT set the switches while the power is supplied.
The switches are used only for maintenance without the power.

## **■** ENVIRONMENT

- Indoor use.
- When heavy dust or metal particles are present in the air, install the unit inside proper housing with sufficient ventilation.
- Do not install the unit where it is subjected to continuous vibration. Do not subject the unit to physical impact.
- Environmental temperature must be within -10 to +55°C (14 to 131°F) with relative humidity within 30 to 90% RH in order to ensure adequate life span and operation.

## **■** WIRING

- Do not install cables close to noise sources (relay drive cable, high frequency line, etc.).
- Do not bind these cables together with those in which noises are present. Do not install them in the same duct.

## ■ AND ....

The unit is designed to function as soon as power is supplied, however, a warm up for 10 minutes is required for satisfying complete performance described in the data sheet.

## INSTALLATION

Use the Installation Base (model: R5-BS).




# **COMPONENT IDENTIFICATION**

## ■ SIDE VIEW

# 1 2 3 4 5 6 7 8 Counter Reset

### **■** FRONT VIEW



Note 1: Counter Reset SW is normally OFF during operation. Note 2: Be sure to set unused SW1 through 7 to OFF.

## **■ STATUS INDICATOR LED**

RUN indicator: Bi-color (red/green) LED;

Red when the bus A operates normally; Green when the bus B operates normally; Amber when both buses operate normally.

Input status indicator: Red LED; turns on with the inputs supplied.

# **PC CONFIGURATOR**

With configurator software, settings shown below are available. Refer to the software manual of R5CON for detailed operation.

## **■ CHANNEL INDIVIDUAL SETTING**


PARAMETER	AVAILABLE RANGE	DEFAULT SETTING
Span	100 to 60000	10000




# **TERMINAL CONNECTIONS**

Connect the unit as in the diagram below.

## ■ EXTERNAL DIMENSIONS unit: mm (inch)



## **■ CONNECTION DIAGRAM**



\*For dual redundant communication.

# **WIRING INSTRUCTIONS**

## ■ SCREW TERMINAL

Torque: 0.8 N⋅m

# **COUNTER RESET**

- 1) Remove Network Module or its cables and interrupt communication with other devices.
- 2) Turn ON the Counter Reset SW (SW8) on R5T-PA2 module.
- 3) Return the module to the base and turn the power supply on.
- 4) Red RUN LED turns on and the module starts resetting its counter. When the resetting is complete, the LED turns to green. DO NOT remove the power while the red LED is on.
- 5) After the green LED is confirmed, turn the power supply off.
- 6) Turn OFF the Counter Reset SW (SW8).
- 7) Return the Network module onto the base and turn the power supply on.

Note: Counter Reset SW must be turned OFF after this procedure because the module does not start counting with ON state.